

**MATERIAL REACTION TO FIRE CLASSIFICATION  
REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE  
REGULATION DATED NOVEMBER 21<sup>ST</sup>, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)**

Valid five years from issue date

**CERTIFICATE N°19-00092 L**

And appendices of 4 pages

**MATERIAL presented by:** DICKSON PTL  
RUE DES CHARTINIÈRES  
01120 DAGNEUX  
FRANCE

**TRADE NAME:** 4991

**BRIEF DESCRIPTION:** Glass fabric with inherent fire resistant PVC coating on both sides  
Nominal surface weight: 600 +/- 50 g/m<sup>2</sup>  
Nominal thickness: 0.43 +/- 0.03 mm  
Colours: various

**TEST REPORT:** N°19-00092 E1 - V1 on the January 24th, 2019

**TESTS:** Electrical burner test

**CLASSIFICATION:** **M 1**

**CLASSIFICATION DURATION (article 5 of appendix 2): unlimited unless otherwise specified**

given the criteria resulting from the tests described in the enclosed test report.


The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated March 14, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

**Issued in Lyon, France, on the January 24th, 2019**



**Laure ATCHADE**  
Engineer Tests and Trials



**Jean-Marc ORAISON**  
In charge of Fire Regulation