

**MATERIAL REACTION TO FIRE CLASSIFICATION**  
**REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE**  
**REGULATION DATED NOVEMBER 21<sup>ST</sup>, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)**

Valid five years from issue date

**CERTIFICATE N°18-03046 L**

And appendices of 4 pages

**MATERIAL presented by:**

**DICKSON SAINT CLAIR**  
415 AVENUE DE SAVOIE  
ST CLAIR DE LA TOUR  
38357 LA TOUR DU PIN CEDEX  
FRANCE

**TRADE NAME:**

**TEXTURA**

**BRIEF DESCRIPTION:**

**Polyester fabric with inherent flame retardant PVC coating on both sides**  
**Nominal surface weight: 375 g/m<sup>2</sup>**  
**Nominal thickness: 0.33 mm**  
**Colours: various**

**TEST REPORT:**

**N°18-03046 E1 - V1 on November 14<sup>th</sup>, 2018**

**TESTS:**

**Electrical burner test**

**CLASSIFICATION:**

**M 2**


**CLASSIFICATION DURATION (article 5 of appendix 2): unlimited unless otherwise specified**

given the criteria resulting from the tests described in the enclosed test report.


The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law article L.433-3 n°2016-301 dated March 14<sup>th</sup>, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

**Issued in Lyon, France, on the November 14<sup>th</sup>, 2018**



**Sophie GUINAMAND**  
Engineer Tests and Trials



**Jean-Marc ORAISON**  
In charge of Fire Regulation